

Certificate

Applicant: **KOSTAL Solar Electric GmbH**
Hanferstr. 6
79108 Freiburg i. Br.
Germany

Product: **PV Inverter**

Model:	PIKO 36 EPC
Rating:	36kW

Intended use:

Photovoltaic inverter in accordance with CLC/TS 50549-1 with three-phase parallel coupling to the distribution network. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

CLC/TS 50549-1:2015

Requirements for generating plants to be connected in parallel with distribution networks
Part 1: Connection to a LV distribution network above 16A

A representative product was successfully tested and corresponds at the time of issue of this certificate to the requirements of the applied standard.

Report No: 16PP342-18

Certificate No: 17-243-00

Date of issue: 2017-07-11



Andreas Aufmuth
Certification Department

